




。 DIMENSIONS 規格尺寸

TDV


UNIT :mm




TDV + PF085A + FH-3 x2



TDV + US-08







TDV + P3G-08



。 OPERATION 操作方式

TDV



COM. : Common terminal
 N.C. : Normally closed contact
 N.O. : Normally open contact
 : Flicker out contact
 : Instantaneous contact

- NOTE:
- 。 Set time should be greater than min. operation time.
 - 。 Once power is cut off or timing operation is completed, Power off time is needed to start the operation again.
 - 。 Do not change the set time during operation.
 - 。 When changing set time, cut off power and set the time.